



The Public Health and Safety Organization

CLOSE WINDOW TO EXIT NSF LISTINGS ►

NSF Product and Service Listings

These NSF Official Listings are current as of **Monday, November 17, 2014** at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

<http://info.nsf.org/Certified/DWTU/Listings.asp?CompanyName=selecto&>

Note: Certain claims, such as Arsenic (Pentavalent) Reduction, appear as active links, allowing you to access additional information regarding the specific contaminants.

NSF/ANSI 42 Drinking Water Treatment Units – Aesthetic Effects

NOTE: All Replacement Elements Are Components.

Selecto Scientific,
Inc.

3980 Lakefield Court
Suwanee, GA 30024
United States
800-635-4017
678-475-0799



[Visit this company's website](#)

Facility : Suwanee, GA

Brand Name / Trade Name / Model	Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim
Plumbed-In				
IC600[Pb]	101-390	15,000	5	Chlorine Reduction Taste and Odor Reduction
IC600Plus	101-390	15,000	5	Chloramine Reduction Taste and Odor Reduction
IC620[Pb]	101-300	100,000	5	Chlorine Reduction Taste and Odor Reduction
IL-35	N/A	3000	2	Chlorine Reduction Taste and Odor Reduction
MF IC620[Pb]	101-300	22,500	3	Chloramine Reduction Taste and Odor Reduction
QC500	QC500-2	5000	2.5	Chlorine Reduction Taste and Odor Reduction
QCM 350[Pb]	105-510	20,000	1.7	Chlorine Reduction Taste and Odor Reduction
QCM 350+[Pb]	105-504	20,000	1.7	Chlorine Reduction Taste and Odor Reduction
QCM 350S[Pb]	105-505	20,000	1.7	Chlorine Reduction Taste and Odor

QCM 500[Pb]	105-500	40,000	2.5	Reduction Chlorine Reduction Taste and Odor Reduction
QCM 500S[Pb]	105-501	40,000	2.5	Chlorine Reduction Taste and Odor Reduction
SMF IC 600CC[Pb]	108-010	8000	2	Chloramine Reduction Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF IC 600CC-S[Pb]	108-010S	8,000	2	Chloramine Reduction Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF IC 614C[Pb]	108-014	75,000	7	Chlorine Reduction Taste and Odor Reduction Nominal Particulate Reduction, Class I
SMF IC620C-S[Pb]	108-020S	22,500	3	Chloramine Reduction Nominal Particulate Reduction, Class I Taste and Odor

SMF IC620plus[Pb]	108-020	16,000	4	Reduction Chloramine Reduction Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC600[Pb]	108-010	50,000	5	Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC600-S[Pb]	108-010S	50,000	5	Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC614[Pb]	108-014	15,000	3.7	Chloramine Reduction Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC614-S[Pb]	108-014S	15,000	3.7	Chloramine Reduction Nominal Particulate Reduction, Class I Taste and Odor

SMF-IC614C-S[Pb]	108-014S	75,000	7	Reduction Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC620[Pb]	108-020	100,000	10	Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC620 C[Pb]	108-020	22,500 (1)	3	Chloramine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC620 CC[Pb]	108-020 (2)	45,000 (1)	6	Chloramine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC620 CCC[Pb]	108-020 (3)	67,500 (1)	9	Chloramine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMF-IC620-S[Pb]	108-020S	100,000	10	Chlorine Reduction Nominal

				Particulate Reduction, Class I Taste and Odor Reduction
SMFIC620-2[Pb]	108-020 (2)	200,000	10	Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction
SMFIC620-3[Pb]	108-020 (3)	300,000	15	Chlorine Reduction Nominal Particulate Reduction, Class I Taste and Odor Reduction

(1) Claims of capacity or rated service cycle are not applicable for mechanical filtration.

[Pb] Product also evaluated and determined to possess weighted average lead content of

<=0.25% and complies with lead content requirements for “lead free” plumbing as defined

by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking

Water Act.

NOTE: All replacement elements are components.

Selecto Scientific,
Inc.

3980 Lakefield Court
Suwanee, GA 30024
United States
800-635-4017

Facility : # 1 USA

Brand Name / Trade Name / Model	Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim
Plumbed-In				
QC110	QC110-C	2500	.5	Chlorine Reduction Taste and Odor Reduction
QC112	QC112-C	3000	.5	Chlorine Reduction Taste and Odor Reduction
QC112-L	QC112-CL	1500	.5	Chlorine Reduction Taste and Odor Reduction
QC350	N/A	15,000	1.67	Chlorine Reduction Taste and Odor Reduction
QC350-S	N/A	15,000	1.67	Chlorine Reduction Taste and Odor Reduction
QC500	N/A	20,000	2	Chlorine Reduction Taste and Odor Reduction
QC500-S	N/A	15,000	1.67	Chlorine Reduction Taste and Odor Reduction

NOTE: All replacement elements are components.

NSF/ANSI 53

Drinking Water Treatment Units - Health Effects

Selecto Scientific,
Inc.
3980 Lakefield Court



Suwanee, GA 30024
 United States
 800-635-4017
 678-475-0799
[Visit this company's website](#)

Facility : Suwanee, GA

Brand Name / Trade Name / Model	Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim
Plumbed-In				
SMF IC 600CC[Pb]	108-010	(1)	2	Cyst Reduction
SMF IC 600CC-S[Pb]	108-010S	(1)	2	Cyst Reduction
SMF IC 614C[Pb]	108-014	(1)	7	Cyst Reduction
SMF IC620C-S[Pb]	108-020S	(1)	3	Cyst Reduction
SMF-IC600[Pb]	108-010	(1)	5	Cyst Reduction
SMF-IC600-S[Pb]	108-010S	(1)	5	Cyst Reduction
SMF-IC614[Pb]	108-014	(1)	3.7	Cyst Reduction
SMF-IC614C-S[Pb]	108-014S	(1)	7	Cyst Reduction
SMF-IC620[Pb]	108-020	(1)	10	Cyst Reduction
SMF-IC620 C[Pb]	108-020	(1)	3	Cyst Reduction
SMF-IC620 CC[Pb]	108-020 (2)	(1)	6	Cyst Reduction
SMF-IC620 CC[Pb]	108-020 (3)	(1)	6	Cyst Reduction
SMF-IC620 CCC[Pb]	108-020 (3)	(1)	9	Cyst Reduction
SMF-IC620-S[Pb]	108-020S	(1)	10	Cyst Reduction
SMFIC620-2[Pb]	108-020 (2)	(1)	10	Cyst Reduction
SMFIC620-3[Pb]	108-020 (3)	(1)	15	Cyst Reduction

(1) Claims of capacity or rated service cycle are not applicable for mechanical filtration.

[Pb] Product also evaluated and determined to possess weighted average lead content of

<=0.25% and complies with lead content requirements for “lead free” plumbing as defined

by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

NOTE: All replacement elements are components.

Selecto Scientific, Inc.

3980 Lakefield Court
Suwanee, GA 30024
United States
800-635-4017

Facility : # 1 USA

Brand Name / Trade Name / Model	Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim
Plumbed-In				
QC110	QC110-C	(1)	.5	Cyst Reduction
QC112	QC112-C	(1)	.5	Cyst Reduction
QC112-L	QC112-CL	1500	.5	Cyst Reduction Lead Reduction
QC350	N/A	(1)	1.67	Cyst Reduction
QC350-S	N/A	(1)	1.67	Cyst Reduction

(1) Claims of capacity or rated service cycle are not applicable for mechanical filtration.

NOTE: All replacement elements are components.

Number of matching Manufacturers is 4
Number of matching Products is 56
Processing time was 0 seconds

- Connect with NSF    

©2012 NSF International. All rights reserved.