



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI Standard 53 - Drinking Water Treatment Units - Health Effects

This is the Official Listing recorded on November 15, 2011.

Selecto Scientific, Inc.
3980 Lakefield Court
Suwanee, GA 30024
800-635-4017
678-475-0799

Facility: Suwanee, GA

Brand Name / Trade Name / Model	Replacement Element	Service Cycle (gallons)	Flow Rate (gpm)	Claim
Point-of-Entry ^[2]				
MF620C	101-298Z	(1)	5	Cyst Reduction
	101-300			Turbidity Reduction
MF620CC	101-298Z(2)	(1)	5	Cyst Reduction
	101-300			Turbidity Reduction
Plumbed-In ^[2]				
MFIC620	101-300	(1)	5	Cyst Reduction
NanoSmart WT920	101-920	(1)	6.5	Cyst Reduction
SMF-IC600	108-010	(1)	5	Cyst Reduction
SMF-IC614	108-014	(1)	3.7	Cyst Reduction
SMF-IC620 ^[Pb]	108-020	(1)	10	Cyst Reduction
SMF-IC620 CC ^[Pb]	108-020(3)	(1)	6	Cyst Reduction
SMFIC620-2 ^[Pb]	108-020(2)	(1)	10	Cyst Reduction
SMFIC620-3 ^[Pb]	108-020(3)	(1)	15	Cyst Reduction

(1) Claims of capacity or rated service cycle are not applicable for mechanical filtration.

[2] Listing does not include post filter gauge/relief valve mechanism.

[Pb] Product also evaluated and determined to possess weighted average lead content of $\leq 0.25\%$ and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193.

NOTE: All replacement elements are components.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.